



NOTES

1. DELETED.
2. DELETED.
3. DELETED.
4. JETTY HEAD ISOLATION VALVES ARE CLOSED TO TERMINATION OF JETTY HEAD AREA.
5. DELETED.
6. DELETED.
7. SLOW CLOSE 30-90 SECONDS.
8. DELETED.
9. DELETED.
10. PROVIDE A THREE WAY VALVE OR INTERLOCKED PAIR OF VALVES TO GUARANTEE A RELIEF PATH TO THE STORAGE TANKS.
11. DELETED.
12. DELETED.
13. CONNECTION FOR PORTABLE PUMP TO BE LOCATED AT LOW POINT.
14. RETURN FROM PORTABLE PUMP, RETURN TO CIRCULATION LINE TO DRAIN. DRAIN LINE AND RETURN TO LOADING LINE TO DRAIN CIRCULATION LINE.
15. DISTANCE BETWEEN ESBV AND HAZARDOUS EQUIPMENT IN THE FIRE ZONE SHOULD CONFORM TO THE RESULTS OF THE CONSEQUENCE ANALYSIS (REF DOC. NC-1716-898-1900-001). IF NOT PRACTICABLE THE MINIMUM DISTANCE SHALL BE 15 M FROM UNIT EDGE AND THE ESBV AND ASSOCIATED PIPING SHALL BE PROTECTED.
16. PHASE 7 & 8 EPCO CONTRACTOR SHALL PROVIDE ENOUGH 10 SIGNALS IN THE ORDER TO FULL SUPERVISE AND MONITOR THE LOADING DEPENDANT ON DETAILS BY OTHERS.
17. DELETED.
18. CONNECTED EITHER TO PHASE 7 OR 18.
19. LINES TO BE CONNECTED TO FT HEADER IN PAID PID-1716-160-004-004.
20. DELETED.
21. CONNECTION FOR FUTURE PHASES PROPANE EXPORT/CIRCULATION COMMON HEADERS, HAS BEEN PROVIDED IN PID-1716-160-004-005 THE OPERATING PHILOSOPHY OF COMMON HEADER TO BE FINALLIED BY OTHER.
22. DELETED.
23. INTERLOCK PREVENTS REGR. VALVES FROM CLOSING SIMULTANEOUSLY DURING HOLDING MODE.
24. RESTRICTION ORIFICE TO BE INSTALLED INSTEAD OF SPACER CONSIDERING OTHER PHASES OPERATION.

GENERAL NOTES

ALL INSTRUMENT TAGS TO READ:
LETTERS
NUMBER
1481
FFFF
NNNN

IS APPLICABLE ONLY FOR PIPING DESIGN SCOPE NOT FOR SUPPLY SCOPE.

EQUIPMENT LIST

FT	PID-1716-160-004-004 (SEE NOTE 19)
FT	PID-1716-160-004-004 (SHEET 1 OF 2)
FL	PID-1716-160-004-004 (SHEET 2 OF 2)
DP	PID-1716-160-004-005

UTILITY PID NUMBER

FT	PID-1716-160-004-004 (SEE NOTE 19)
FT	PID-1716-160-004-004 (SHEET 1 OF 2)
FL	PID-1716-160-004-004 (SHEET 2 OF 2)
DP	PID-1716-160-004-005

FOR CONSTRUCTION

REV	DATE	DESCRIPTION	ORIG	PREP	CHKD	APPD	AUTH
-----	------	-------------	------	------	------	------	------

SOUTH PARS GAS FIELD DEVELOPMENT-
PHASES 17 & 18, ASSALUYEHAH-IRAN
ONSHORE FACILITIES